

ARAWA ROAD - ESZ

System Curve Calculation (Hazen-Williams Formula)

C:\Users\lmc1\Downloads\COPY Arawa Road analysis and reference information PvdBerg 05 2024.xls\Arawa Rd 2016 (Hazen-Williams)

change green highlighted cells only

Flow	[l/s]	0	1	2	3	4	6	8
Flow	[m ³ /s]	0	0.0010	0.0020	0.0030	0.0040	0.0060	0.0080

RISING MAIN

Pipe OD	[mm]							
Pipe ID	[mm]	93						
Pipe Roughness		140	Hazen 'C'					
Mainline Length	[m]	2100						
Pipe Area	[m ²]	0.006793						
Velocity	[m/s]	0.00	0.15	0.29	0.44	0.59	0.88	1.18
Hydraulic Radius	[m]	0.02325						
Friction Loss	[m/m]	0.000	0.000	0.001	0.003	0.004	0.009	0.016


FRICITION LOSSES

Rising Main Loss	[m]	0.00	0.70	2.52	5.34	9.09	19.26	32.81
------------------	-----	------	------	------	------	------	-------	-------

MINOR LOSSES

Minor Losses (5%)	[m]	0.000	0.035	0.126	0.267	0.454	0.963	1.640
-------------------	-----	-------	-------	-------	-------	-------	-------	-------

SYSTEM CURVE	[m]	0.00	0.73	2.64	6	9.54	20.22	34.45
---------------------	------------	-------------	-------------	-------------	----------	-------------	--------------	--------------



Arawa Road Pongakawa, 2.01 km 100mm NB MDPE Water main.

elevation at pipe start mRL		5	5	5	5	5	5
pressure at pipe start		65	65	65	65	65	65
head losses through pipe		0.73	2.64	5.60	9.54	20.22	34.45
elevation at pipe end mRL		5	5	5	5	5	5
elevation change mRL		0	0	0	0	0	0
energy head at pipe start m		70	70	70	70	70	70
energy head at pipe end m		69	67	64	60	50	36
Pressure at pipe end m		64	62	59	55	45	31

Calculations for typical average domestic demand on a reticulation system

	Current	Future	
Connections	64	93	
People / hh	3.1	3.1	
Daily demand /per	220	220	
Total daily demand	43648	63426	
Leakaage at 20%	8729		
TOTAL Demand	52377	76111	76111
Average Flow l/sec	0.61	0.88	1.76
Peak Factor 4.27 (above 30 dwellings)	2.6	3.76	7.5152
Usage over		24 HR	12HR

ARAWA ROAD - ESZ

System Curve Calculation (Hazen-Williams Formula)

C:\Users\lmc1\Downloads\COPY Arawa Road analysis and reference information PvdBerg 05 2024.xls\Hazen Williams Exist 100mm main

change green highlighted cells only

Flow	[l/s]	0	1	2	3	4	6	8
Flow	[m³/s]	0	0.0010	0.0020	0.0030	0.0040	0.0060	0.0080

RISING MAIN

Pipe OD	[mm]							
Pipe ID	[mm]	93						
Pipe Roughness		140	Hazen 'C'					
Mainline Length	[m]	2100						
Pipe Area	[m²]	0.006793						
Velocity	[m/s]	0.00	0.15	0.29	0.44	0.59	0.88	1.18
Hydraulic Radius	[m]	0.02325						
Friction Loss	[m/m]	0.000	0.000	0.001	0.003	0.004	0.009	0.016


FRICTION LOSSES

Rising Main Loss	[m]	0.00	0.70	2.52	5.34	9.09	19.26	32.81
------------------	-----	------	------	------	------	------	-------	-------

MINOR LOSSES

Minor Losses (5%)	[m]	0.000	0.035	0.126	0.267	0.454	0.963	1.640
-------------------	-----	-------	-------	-------	-------	-------	-------	-------

SYSTEM CURVE	[m]	0.00	0.73	2.64	6	9.54	20.22	34.45
---------------------	------------	-------------	-------------	-------------	----------	-------------	--------------	--------------



Arawa Road Pongakawa, 2.01 km 100mm NB MDPE Water main.

reservoir top elevation = 68m

elevation at pipe start mRL		5	5	5	5	5	5
pressure at pipe start		63	63	63	63	63	63
head losses through pipe		0.73	2.64	5.60	9.54	20.22	34.45
elevation at pipe end mRL		7	7	7	7	7	7
elevation change mRL		-2	-2	-2	-2	-2	-2
energy head at pipe start m		68	68	68	68	68	68
energy head at pipe end m		67	65	62	58	48	34
Pressure at pipe end m		60	58	55	51	41	27

Calculations for typical average domestic demand on a reticulation system

	Arawa	+ Penelope	+ Pencarrow	
Connections	64	29	130	223
People / hh	3.1	3.1	3.1	3.1
Daily demand /per	220	220	220	220
Total daily demand	43648	19778	0	88660
Leakage at 20%	8729	3955.6	0	17732
TOTAL Demand	52377	23733.6	0	106392
Average Flow l/sec	0.61	0.88	1.23	
Peak Factor 4.27 (above 30 dwellings)	3.05	0.00	3.76	0.00
Usage over 24 HR				

$3.05 + 0.88 + 1.23 = 5.2 \text{ l/sec}$

System Curve Calculation (Hazen-Williams Formula)

C:\Users\lmc1\Downloads\Copy Arawa Road analysis and reference information PvdBerg 05 2024.xls\Hazen-Williams New 200mm main

change green highlighted cells only

Flow	[l/s]	0	10	20	25	40	50	60
Flow	[m ³ /s]	0	0.010	0.020	0.025	0.040	0.050	0.060

RISING MAIN

Pipe OD	[mm]							
Pipe ID	[mm]	191						
Pipe Roughness		140	Hazen 'C'					
Mainline Length	[m]	2100						
Pipe Area	[m ²]	0.0286521						
Velocity	[m/s]	0.00	0.35	0.70	0.87	1.40	1.75	2.09
Hydraulic Radius	[m]	0.04775						
Friction Loss	[m/m]	0.000	0.001	0.003	0.004	0.009	0.014	0.020

FRICITION LOSSES

Rising Main Loss	[m]	0.00	1.49	5.38	8.13	19.42	29.35	41.14
------------------	-----	------	------	------	------	-------	-------	-------

MINOR LOSSES


Minor Losses (5%)	[m]	0.000	0.075	0.269	0.407	0.971	1.468	2.057
-------------------	-----	-------	-------	-------	-------	-------	-------	-------

SYSTEM CURVE	[m]	0.00	1.56	5.65	9	20.39	30.82	43.20
---------------------	------------	-------------	-------------	-------------	----------	--------------	--------------	--------------

SH2 Main from Kaikokopu to Arawa Rd

elevation at pipe start mRL	5	5	5	5	5	5
pressure at pipe start m	63	63	63	63	63	63
head losses through pipe m	2	6	9	20	31	43
elevation at pipe end mRL	7	7	7	7	7	7
elevation change m		-2	-2	-2	-2	-2

energy head at pipe start m	68	68	68	68	68	68
energy head at pipe end m	66	62	59	48	37	25
Pressure at pipe end m	59	55	52	41	30	18



50 l/sec and 31 meters head loss

Budget Tracking - Western Bay Pump Station 25 customers

Company	Project Description	Due Date for Completion	Quote Rec'd (Objective Ref)	Purchase Order / Contract No.	Quote Cost (Plus GST)
Mishmish	Archaeology				NA
CKL	Design work				NA
CKL					NA
CKL					NA
Consultant Designer	Design works				NA
Civil Construction	Physical Works				NA
Waiotahi	VO - tank & pump area ground prep				\$ 107,115.47
Bay Pumps	Booster Pump Station				\$ 15,318.75
Bay Pumps	Boost pump 5 l/sec				\$ 12,181.31
Tiaki	As-builts				\$ 9,840.00
The Shed Shop	Pump Shed				\$ 11,000.00
Eagle Eye	Electrical				\$ 120.00
Eagle Eye	Electrical				\$ 2,695.00
Eagle Eye	Pillar Supply Installation				\$ 53,580.00
Eagle Eye	Internal Electrical for Pump Station				\$ 41,845.08
Sub Total					\$ 253,695.61
	50 l/sec pump set add \$55,000 for dual pump system with VSDs				55,000
Total					\$ 308,695.61

Western Bay new 30 customers			
	Qty	Unit	Rate Total
1 PUMP STATION WORKS - Bay Pumps			41432
1.1 Supply and install:			
3m x 4m Shed with barn door and entry door (estimate 4 week build time , they will build onsite once floor is done) Shed will be fully lined with 12mm ply except for doors. 1 x 100mm Khrone zero rated mag meter with 10m cable, wall mount convertor and potting of meter terminations. (currently in stock) Installation of an ARV Full plumbing in shed with S/S 100mm Pipe Duel Lowara Sv pumpset without drives but includes pressure transducers and over temp switches. Full labour for the above works Subtotal:			
			41432
2 Electrical - Steve and Downers			
2.1 Electrical Design - Steve		LS	10000
2.2 Physical works: switchboard, VSD and analysers - PO 58339		LS	73974.91
Subtotal:			83974.91
3 Controls - NZ Controls			
Supply, install and commission controls for new PS - PO			
3.1 57950		LS	7762
Supply unmanaged 8 port switch - PO 58857		LS	406
Subtotal:			8168
4 Watermain Installation and Civil Works - Loveridge			
Concrete slab, ground improvement, pipe connections and commision - PO 58354			
4.1	1	LS	42642
Subtotal:			42642
5 Design and Documentation - CKL			
5.1 Design Review and Documentation - Drawings and Specs	1	LS	10000
V01 - Additional Works	1	LS	1225
			0
Subtotal:			11225
All			TOTAL 187441.91
Note for 20 house pump.			
Add 55,000 for 50 l/sec dual pump system with VSDs			
TOTAL			242,442

Table 11.1 Pricing Schedule for 1 X FBE Steel Panel Tank 300m3		
Item	Description	Amount excl.
P & G	Preliminaries and General in including Health & Safety to latest specifications	\$7,300.00
Foundation design	Supply adjusted engineering design drawings for civil concrete foundations to latest specifications	\$8,629.20
Tank	Supply and construction of 1 x Fusion Bonded Epoxy storage tank and ancillaries as set out in tables 8.1 and 9.1	\$147,630.41
	Supply and construction of 1 X reinforced concrete foundations as set out in table 7.1	\$59,637.82
Scour	Supply and installation of 1 x 100nb scour pipe	\$7,866.17
Leak testing	Undertake 3 day leak test on tanks	\$5,961.96
TOTAL INVESTI		\$243,455.83
		+GST NZD

Tank Specifications	
Diameter:	8.529 metres
Floor area:	57.267 m ²
Wall height:	6.338 metres less 125mm in the rebate
Gross capacity:	355.799 m ³
Finished floor level:	0.000 RL (Assumed)
Topwater level:	5.239 RL
Bottom water level:	0.000 RL
Eaves level:	6.213 RL) Freeboard: 974 mm
Nett capacity:	300.00 m ³ (Between TWL and BWL)
Water height:	5,239 mm (Between TWL and FFL)
Application:	Potable water
Ancillaries:	1 x 800mm epoxy coated mild steel low level manway

Budget - Option 2 - Pencarrow - Reservoir and Pump system			
item	description	unit	Cost ex GST
1	Pump Station and switchboard power	incl'	310,000
2	Reservoir	incl'	275,000
3	Pipework, control valves on site	PC	30,000
4	Telemetry, comms, controls, monitors	PC	60,000
5	Site / civil / security / access	PC	65,000
6	Land value	300m2	200,000
Total estimate ex GST			\$ 940,000.00

Budget - Option 1 - Pencarrow - New Water Main upgrade		
Item	Summary of Prices	
1	Preliminary and General	79140
2	Sediment Control and Environmental Works	8500
3	Traffic Management	62500
4	Works	753925
5	Sundry and Provisional items	50000
Total estimate ex GST		\$ 954,065.00

Water Main - SH2 Kaikokopu to Arawa Road - 250 OD PE100 class PN13.6.					
Item	Description	Unit	Quantity	Rate	Amount
1 Preliminary and General					
1.1	Establishment and Disestablishment	L.S.	1	2,500	2,500
1.2	Supervision and Communication	L.S.	1	8,000	8,000
1.3	Documentation, Bonds and Insurances	L.S.	1	2,500	2,500
1.4	Site Specific Health and Safety Plan	L.S.	1	320	320
1.5	Traffic Management Plans	L.S.	1	2,500	2,500
1.6	Environmental Management Plan	L.S.	1	480	480
1.7	Contractor's Quality Plan	L.S.	1	640	640
1.8	Location of Services	L.S.	1	55,000	55,000
1.9	Construction Progress Reports	L.S.	1	1,200	1,200
1.10	As-Built Information	L.S.	1	6,000	6,000
Subtotal section 1 carried to summary					79,140
2 Sediment Control and Environmental Works					
2.1	Sediment Control Works for duration of contract	L.S.	1	2,500	2,500
2.2	Dust Control	L.S.	1	2,500	2,500
2.3	Catchpit inlet Protection	L.S.	1	3,500	3,500
Subtotal section 2 carried to summary					8,500
3 Traffic Management					
3.1	Hire TM services, all equipment, set up and monitoring	per week	5	12,500	62,500
Subtotal section 3 carried to summary					#####
4 Works					
4.1	supply and install watermain 250 OD SDR13.6 PE100 connect new 250 OD SDR13.6 PE100 water main to	m	2100	300	630,000
4.2	existing 300mm PE pipe.	L.S.	1	22,500	22,500
4.3	connect to Arawa Rd retic	L.S.	1	12,500	12,500
4.4	transfer connections	L.S.	15	895	13,425
4.5	connections to development	L.S.	1	15,500	15,500
4.6	Sundry construction from design	P.C.	1	60,000	60,000
Subtotal section 4 carried to summary					753,925
5 Sundry and Provisional items					
5.1	Change alignment for services clashes	L.S.	1	50,000	50,000
Subtotal section 5 carried to summary					50,000
Summary of Prices					
1	Preliminary and General				79140
2	Sediment Control and Environmental Works				8500
3	Traffic Management				62500
4	Works				753925
5	Sundry and Provisional items				50000
TOTAL					\$ 954,065